

FILENAME: C:\Users\bravo\Documents\02-18022_HOU_Restroom_Renovations_MEP_CENTRAL_R19_Bravo@voltairinc.com.rvt
 STAMP: 3/25/2020 4:41:01 PM

KEYNOTES	
NUMBER	NOTES
1	CONTRACTOR TO REINSTALL PEOPLE COUNTER IN CEILING ABOVE RESTROOM ENTRANCE. CONTRACTOR TO VERIFY EXACT LOCATION WITH HAS/ARCHITECT PRIOR TO INSTALLATION.
2	CONTRACTOR TO PROVIDE USB RECEPTACLE MODEL "USB2045W" IN RECESSED BOX TO PROVIDE POWER TO FOR CUSTOMER SATISFACTION METER. CONTRACTOR TO VERIFY EXACT LOCATION AND HEIGHT FOR METER PRIOR TO INSTALLATION WITH ARCHITECT/CIENT.
3	CONTRACTOR TO PROVIDE 120V POWER TO FAUCET AND SOAP DISPENSER LOCATED ON VANITY IN RESTROOMS.
4	CONTRACTOR TO PROVIDE 208V POWER TO HAND DRYER LOCATED ON VANITY IN RESTROOMS.
5	PROVIDE 120V CONNECTION VIA JUNCTION BOX(HARDWIRES) FOR TOILET SENSOR TYPICAL FOR ALL WHERE SHOWN.
6	CONTRACTOR TO PROVIDE POWER AND DATA FOR MONITOR TO BE INSTALLED AT ENTRANCE TO MEN/WOMEN'S RESTROOM. CONTRACTOR TO VERIFY EXACT LOCATION AND MOUNTING HEIGHT WITH OWNER/REP PRIOR TO ROUGH-IN.

GENERAL NOTES	
A.	ELECTRICAL CONTRACTOR SHALL REFER TO THE ELECTRICAL SPECIFICATIONS FOR ADDITIONAL DESIGN STANDARDS. THE ELECTRICAL SPECIFICATIONS ARE A BINDING PART OF THE CONSTRUCTION DOCUMENTS.
B.	COORDINATE ALL MOUNTING HEIGHTS AND LOCATIONS WITH ARCHITECTURAL ELEVATIONS AND CASEWORK DRAWINGS PRIOR TO ROUGH-IN OF ANY RECEPTACLE OR OUTLET DEVICE. CONTRACTOR SHALL MAKE NECESSARY MODIFICATIONS TO DEVICES SHOWN TO PREVENT ANY INSTALLATION CONFLICTS.
C.	CONTRACTOR SHALL ROUTE ALL CONDUIT SHOWN TO BE CONCEALED.
D.	ALL WIRE SHALL BE COPPER STRANDED.
E.	PRIOR TO ROUGH-IN OF ANY OUTLETS, CONTRACTOR SHALL SCHEDULE AND CONDUCT A WALK THROUGH WITH THE OWNER THE VERIFY EXACT LOCATIONS OF POWER AND DATA LOCATIONS. ALL MODIFICATIONS SHALL BE DOCUMENTED PRIOR TO START OF INSTALLATION.
F.	PROVIDE GFCI PROTECTED RECEPTACLES WHERE SHOWN WITHIN 6' OF SINKS OR LAVATORIES.
G.	ALL SPEAKERS SHOWN SHALL TIE INTO EXISTING SOUND SYSTEM FOR THE TERMINAL.
H.	TIE ALL NEW FIRE ALARM DEVICES INTO EXISTING F.A.C.P SERVING THE AREA.



FLOOR PLAN - GATES 40-43 - POWER 1/4" = 1'-0" 1

CLIENT



HAS AVIATION DEPT.
 16930 JOHN F.
 KENNEDY BLVD.
 HOUSTON TX 77032
 [T] 281 233 1757
 [F] 281 233 1800

ARCHITECT



PGAL
 3131 BRIARPARK DR.
 SUITE 200
 HOUSTON, TX 77042
 [T] 713 622 1444
 [F] 713 968 9333
 www.pgal.com

CONSULTANT



5353 WEST ALABAMA ST
 SUITE 205
 HOUSTON, TX 77056
 T 832 371 6181
 F 832 371 6244
 www.VoltAirinc.com
 Texas Firm #F-14583
 Project # 02.18022

REGISTRATION

Copyright © 2019



DRAWING HISTORY

NO.	DATE	DESCRIPTION
1	2020.03.20	ISSUE FOR PERMIT
2	2020.03.26	ADDENDUM #1

DEPARTMENT OF AVIATION
 RECOMMENDED:

HAS TIP # 19-171 - HOU

PROJECT NAME

HAS HOUSTON
 HOBBY
 AIRPORT

STATUS ISSUE DATE

2020.03.20

PROJECT LOCATION

7800 AIRPORT BLVD
 HOUSTON, TEXAS
 77061

PROJECT NUMBER

1004426

SHEET TITLE

FLOOR PLAN -
 GATES 40-43 -
 POWER

SHEET NUMBER

E3.01