



CITY OF HOUSTON

Sylvester Turner

Mayor



HOUSTON AIRPORT SYSTEM

George Bush Intercontinental ~ William P. Hobby ~ Ellington Airport

Mario C. Diaz
Director of Aviation

October 26, 2023

SUBJECT: Addendum No. 6

REFERENCE: Invitation To Bid (ITB) for the IAH Integrated Coordination Center at George Bush Intercontinental Airport; Solicitation No. H06-IAHICC-2024-004; Project No. 793

To: All Prospective Bidders:

This Addendum is issued for the following reasons:

I. Add the following pages with the attached documents as outlined below.

1. Workstation Consoles.

II. To Respond to the following Question.

1. **Question:** Based on the tile specified being discontinued (BP97 583BJMS1P - Disco'd), would there be an alternate tile specification in lieu of this selection, or shall we put in a dollar allowance for pricing for this material?

Response: Yes, please provide a dollar allowance to cover similar price point material.

When issued, Addendum shall automatically become part of the solicitation documents and shall supersede any previous specification(s) and/or provision(s) in conflict with the Addendum. Addendum will be incorporated into the Agreement as applicable. It is the responsibility of the bidder(s) to ensure that it has obtained all such letter(s). By submitting a bid on this project, bidder(s) shall be deemed to have received all Addendum and to have incorporated them into their bid.

If further clarification is needed regarding this solicitation, please contact Senior Procurement Specialist, David Martinez via email at david.martinez@houstontx.gov.

DocuSigned by:

Cathy Vander Plaats

02232028DE09414...

Cathy Vander Plaats
Aviation Procurement Officer
Houston Airport System

CVP/dm

October 26, 2023

IAH Integrated Coordination Center at George Bush Intercontinental Airport

Solicitation No. H06-IAHICC-2024-004

Project No. 793

cc: Alfredo Oracion
Dallas Evans
Solicitation File

Attachments:

1. Workstation Consoles.

SECTION 125686 – WORKSTATION CONSOLES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
 - 1. Workstation Consoles.

1.3 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Samples: For each finish specified.
- C. Shop Drawings: 2D and 3D views describing all components, functionality, and equipment placement

1.4 QUALITY ASSURANCE

- A. Surface Burning Characteristics: As determined by testing identical products according to ASTM E84 or UL 723 by a qualified testing agency.
 - 1. Flame-Spread Index: Class B, flame spread index 26-75.
 - 2. Smoke Development Index: Class B, not more than 450.
- B. Manufacturer Requirements: According to listed certifications or equivalent.
 - 1. ISO-9001-2008 Certified
 - 2. ISO 14001 Certified or equivalent.
- C. Acceptable Tolerances.
 - 1. Worksurfaces for casework and consoles: 1/64"
 - 2. Metal components: 0.020"
 - 3. Casework Components: 1/64"

IAH Integrated Coordination Center
Project No. PN793

WORKSTATION CONSOLES

1.5 WARRANTY

- A. Manufacturer agrees to repair or replace components that fail in materials or workmanship within specified warranty period.
 - 1. Failures include, but are not limited to, the following:
 - a. Deterioration of finishes beyond normal weathering.
 - b. Separation or delamination of sheet materials and components.
 - 2. Warranty Period: Five years minimum from date of Substantial Completion.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Store resilient products and installation materials in dry spaces protected from the weather, with ambient temperatures maintained within range recommended by manufacturer, but not less than 50 deg F (10 deg C) or more than 90 deg F (32 deg C).

1.7 PROJECT CONDITIONS

- A. Maintain ambient temperatures within range recommended by manufacturer, but not less than 70 deg F (21 deg C) or more than 95 deg F (35 deg C), in spaces to receive resilient products during the following time periods:
 - 1. 48 hours before installation.
 - 2. During installation.
 - 3. 48 hours after installation.
- B. Until Substantial Completion, maintain ambient temperatures within range recommended by manufacturer, but not less than 55 deg F (13 deg C) or more than 95 deg F (35 deg C).
- C. Install products after finishing operations, including painting, have been completed.

PART 2 - PRODUCTS

2.1 TYPICAL WORKSTATION CONSOLE: RB-1

- A. Acceptable Manufacturers:
 - 1. Basis-of-Design Product : Subject to compliance with requirements, provide Evans Response NEXTGen or approved equal.
- B. Console Quality Standards: ISO 11064, ANSI/BIFMA X5.5, ANSI/HFES 100-2007.
 - 1. Maximum load on worksurfaces: 4800N (1080lb-force) with four lift columns.
- C. Sit/Stand Capability: Full console sit to stand height adjustment.
 - 1. Electric drive system with electric actuator to power height adjustment.

IAH Integrated Coordination Center
Project No. PN793

WORKSTATION CONSOLES

2. Lift system must compensate for differential loads from side to side, preventing racking or damage to the structure.
 3. Minimum of 2 heavy-duty electro-mechanical columns with 1200N (270lb-force) load per column.
 4. Worksurface Lift speed: 38 mm/s minimum.
 5. Worksurface height range: 28 inches (559mm) to 47.5 inches (1207mm)
 6. Keyboard platform shall use minimum 2 light-duty electro-mechanical lift columns with 1200N (270lb-force) load per column.
- D. Column Housings:
1. Column housing shall be modular and removable if needed.
 2. Housing to contain all the lifting mechanisms for height adjustment.
 3. Housing to be a self-contained unit providing all structural support for the lift mechanisms as well as required cable management and floor cable/data access.
 4. Provide dedicated cable access ports in each of the column housing units.
- E. Frame Configuration:
1. The span between column housings shall be free of any obstructions and the lowest point of the frame shall be at least 10" from the floor.
 2. Provide modular CPU storage in open frame design.
- F. Cable Management and Technology Raceway:
1. Provide continuous and reconfigurable cable and technology raceways with a minimum of 2 tiers and maximum of 5 tiers. Raceways should be easily accessed from front and rear of console.
 2. Console to have self-contained dynamic cable management system to ensure that cable transition between static and dynamic parts of the console are pre-strained and do not experience any movement, damage, or disconnection.
- G. Technology and Equipment Integration:
1. Provide reconfigurable CPU and technology enclosures.
- H. Worksurface:
1. Shall be supported by structural frame.
 2. Fastening on the underside shall be done using machine screws and appropriate threaded inserts in worksurface core.
- I. Display (Monitor) Management:
1. Slatwall & Slatrail:
 - a. Provide slatwall/slatrail mountings for a minimum of four monitors; slatwall heights must be scalable from single, double, to triple tier configurations.
 - b. Slatwall must be accessible from front and rear.
 - c. Provide brush grommets in every section of slatwall from front to route power and data cords.
 - d. Top of slatwall structure to incorporate edge-lit plexiglass or glass panel for console illumination.

IAH Integrated Coordination Center
Project No. PN793

WORKSTATION CONSOLES

- e. Slatrail frame to be secured directly to console frame using structural grade cast aluminum mounts.
 - f. Slatrail system to be constructed as a single continuous high strength piece.
 - g. Provide casting end treatments at all extrusion edges of slatrail system.
 - h. No exposed hardware on slatrail system.
 - i. Slatrail system to have full horizontal and vertical cable management, with extruded covers that can be removed without tools for all cable management channels.
 - j. No visible welds or exposed formed metal edges permissible on slatwall or slatrail.
 - k. Provide adjustable quick release tilt knuckles for monitor-slatrail mounts.
2. Automated Monitor Management System
- a. Provide an electrical actuated desktop monitor management system capable of manual or automated horizontal and/or vertical movement.
 - b. System to be constructed of steel and aluminum extrusions.
 - c. System to be capable of supporting up to 5 wide x 2 high standard-sized LCD monitors.
 - d. System to be controlled through integrated switch.
 - e. Minimum of 8 inches of horizontal adjustment using 1500N actuator.
 - f. Minimum of 12 inches of vertical adjustment using 800N actuator.
- J. Ergonomics:
1. Worksurface depth and monitor management system shall allow for adequate focal depth adjustment of monitors, at a minimum of 16 inches to 30 inches.
 2. Monitor mounting system with flexibility for required visual arc, and ability to adjust tilt, depth, and height.
 3. Provide soft urethane replaceable worksurface edge.
- K. Materials:
1. Metal components
 - a. Sheet Metal: Cold rolled steel with minimum yield of 27 ksi and modulus of elasticity of 29x10⁶ psi.
 - 1) Structural Components: 14 ga.
 - 2) Panels and other Components: 16 ga.
 - 3) Heavy Duty Mounts/Supports: 10 ga.
 - b. Finish: Powder coat, tested to meet ASTM D5965 (specific gravity), D523 (gloss), D1005 (thickness), D3363 (hardness), D2794 (impact resistance) D522 (mandrel), B117 (salt spray), and D1735/2247 (humidity).
 2. Aluminum Components
 - a. Aluminum alloy 6063-T54 with 30 KSI Yield Strength
 - b. Surface pre-treated with 3-stage cleaning process for steel and aluminum using high alkaline liquid detergents prior to 1-stage iron phosphate coating that meets Federal specifications TT-C-490, Type II
 3. Wood and High Pressure Laminate Panels: Meet or Exceed NEMA standards in following categories.
 - a. Thickness: 0.039 inches +/- 0.005 inches.

IAH Integrated Coordination Center
Project No. PN793

WORKSTATION CONSOLES

- b. Impact Resistance: Greater than 30.
 - c. Surface wear resistance: Meet or exceed 400.
 - d. Stain resistance: No effect for reagents 1-10.
 - e. Radiant heat resistance: Greater than 100 seconds.
4. Solid Surface
- a. Meet standards set in ASTM D636, ASTM D790, ASTM D2583, ASTM D696, ASTM D648, ASTM D256, ASTM D792, ASTM NEMA LD 3-3.03, 3.05, 3.06, 3.08, 3.10, ANSI Z-124-3, ANSI/NSF Standard 51, ISSFA SST 2.10, 3.1-00, 4.1, 5.1, 8.1-00, 7.1, 9.1-00.
- L. Electrical and Data System Requirements:
- 1. Conducive to electrical grounding without modification.
 - 2. Integrated modular power distribution system
 - a. 8-wire / 3-circuit system with NEMA 5-20R receptables in 3-3-2 combination
 - b. Each 20 amp circuits capable of connecting multiple circuit distribution bars to various positions without the need for electrical contractor installation.
 - c. UL certified components
 - d. Armored cable whips
 - e. Ability to control each circuit independently.
 - f. Ability to provide singular power distribution system between multiple console positions
 - g. Color coding around the receptacles to differentiate multiple power sources
- M. Finishes:
- 1. Work surfaces: High pressure laminate, Shadow Zephyr
 - 2. Front, Rear, and End panels: High pressure laminate, Atlantis
 - 3. Work Surface PVC Edging: Black
 - 4. Cable Chains: Black
 - 5. Slatrail inserts: High pressure laminate, Wilsonart Black
 - 6. Plexiglass panel: Clear plexiglass
 - 7. Lift Column Housing: Silver
 - 8. Panel PVC Edging: Atlantis PVC
 - 9. Internal Frame and Accessories: XP Black Santex and Natural Aluminum.
- N. Accessories:
- 1. Environmental Management System:
 - a. Controls: Provide desktop touch controller for environmental management system.
 - b. Task Lighting: Provide two task lights.
 - c. Heater: Provide one compatible forced air heater.
 - d. Fan: Provide two desktop fans.

2.2 INSTALLATION MATERIALS

- A. Manufacturer to provide one set of hand tools required for assembly.

PART 3 - EXECUTION

IAH Integrated Coordination Center
Project No. PN793

WORKSTATION CONSOLES

3.1 PREPARATION

- A. Sweep and vacuum clean surfaces immediately before installation.

3.2 INSTALLATION

- A. Comply with manufacturer's written instructions for assembling and installing.
- B. Manufacturer to provide installation support and site supervision.

3.3 CLEANING AND PROTECTION

- A. Comply with manufacturer's written instructions for cleaning and protection of products.
- B. Perform the following operations immediately after completing product installation:
 - 1. Remove adhesive and other blemishes from exposed surfaces.
 - 2. Sweep and vacuum surfaces thoroughly.
- C. Protect products from mars, marks, indentations, and other damage from construction operations and placement of equipment and fixtures during remainder of construction period.
 - 1. Cover assembled products until Substantial Completion.

END OF SECTION 125686