



CITY OF HOUSTON

Sylvester Turner

Mayor



HOUSTON AIRPORT SYSTEM

George Bush Intercontinental ~ William P. Hobby ~ Ellington Airport

Mario C. Diaz
Director of Aviation

June 27, 2023

SUBJECT: Addendum No. 2

REFERENCE: Invitation To Bid (ITB) H73-FBLL-2023-025 for George Bush Intercontinental Airport (IAH) FIDS and BIDS LED Lights, Phase II Terminal A

To: All Prospective Bidders:

This Addendum is issued for the following reason:

I. To Respond to Questions

1. **Question:** A major portion of the project entails removing NUC/DDC players from the monitors and relocating them to the closest IDF closet. Please provide the necessary cabling length from each FIDS bank to the closest IDF closet.

Response: Means and methods can impact the cable lengths; and therefore, it is the responsibility of the contractor performing the work. HAS will note that the FID bank and the IDF rooms that serve each location are located on the plans with scaled drawings. The pathways area design to fall within the allowable Cat 6 cable length range of 295 linear feet.

2. **Question:** Infax could either prime or sub this project and is trying to determine our best role moving forward. Please provide a list of potential prime candidates or subcontractors that have downloaded or received copies of this RFP.

Response: Visit fly2houston.com and view the pre-bid attendance sheet.

3. **Question:** Can additional site visits be arranged?

Response: Yes.

4. **Question:** Additionally, we will likely need an extension to ask questions after this site visit.

Response: The Bid due date has been extended to July 20, 2023, please refer to Addendum No. 1, dated June 20, 2023.

Addendum No. 2

June 27, 2023

FIDS and BIDS LED Lights, Phase II Terminal A
Solicitation #H73-FBLL-2023-025

When issued, Addendum shall automatically become part of the solicitation documents and shall supersede any previous specification(s) and/or provision(s) in conflict with the Addendum. The addendum will be incorporated into the Agreement as applicable. It is the responsibility of the bidder(s) to ensure that it has obtained all such letter(s). By submitting a bid on this project, bidder(s) shall be deemed to have received all Addenda and to have incorporated them into their bid.

If further clarification is needed regarding this solicitation, please contact Gabriel Carey, Sr. Procurement Specialist, via email at gabriel.carey@houstontx.gov.

DocuSigned by:
Cathy Vander Plaats
02232028DE99414

Cathy Vander Plaats
Aviation Procurement Officer
Houston Airport System

DS
AO

cc: Alfredo Oracion
Dallas Evans
Solicitation File

DS
DE